

Adult Day Care & Child Care Fire Inspection Report

COUNTY _____ DATE OF INSPECTION _____ Facility ID # _____

Please complete all items below. If not applicable, check N/A in the box with a written explanation attached.

Name of Facility _____ Adult _____ Child _____
 Address _____ Telephone _____
 City _____ Zip _____ Responsible Party _____

GENERAL PRECAUTIONS:

- | | YES | NO | NA |
|--|-----|----|----|
| 1. Attic/basement/closets/furnace room & heaters clear of trash & combustible materials. | | | |
| 2. Clearance from ignition sources & combustible materials maintained. | | | |

EMERGENCY PLANNING:

- | | | | |
|---|--|--|--|
| 3. Approved evacuation plan posted. | | | |
| 4. Evidence of monthly fire drills posted. | | | |
| 5. Record of employee training in fire prevention/evacuation & annual fire safety training on site. | | | |

FIRE SERVICE FEATURES:

- | | | | |
|--|--|--|--|
| 6. Street numbers posted. (Contrasting color to building & height 4" or more.) | | | |
| 7. Unobstructed fire apparatus road (width of 20' & vertical clearance of not less than 13' 6"). | | | |
| 8. Hydrants/Fire Department connections/control valves clear of obstructions by 3'. | | | |

BUILDING SERVICES AND SYSTEMS:

- | | | | |
|--|--|--|--|
| 9. Approved heating system, listed. (No fuel burning space heaters.) | | | |
| 10. Emergency lighting/exit lights in good operating order. | | | |
| 11. Electrical panels clear of storage (minimum 30"). | | | |
| 12. Wiring/fixtures in good condition. (Extension cords not suitable for permanent wiring.) | | | |
| 13. Type I hood system over all domestic cooking appliances that produce grease laden vapors | | | |

FIRE RESISTANCE RATED CONSTRUCTION:

- | | | | |
|--|--|--|--|
| 14. Required fire resistant rating maintained. (Walls, partitions, floors) | | | |
| 15. Door-hold open devices/automatic door closures operating properly. | | | |

INTERIOR DECORATIONS & FURNISHINGS:

- | | | | |
|---|--|--|--|
| 16. No storage of clothing/personal effects in corridors & lobbies | | | |
| 17. Maximum 10% of decorative materials covering walls. Does not apply to artwork & teaching material in classroom. Nothing suspended from ceiling. | | | |
| 18. 20% maximum coverage for artwork & teaching material located on corridor walls. | | | |
| 19. Exits free of obstructions. | | | |

FIRE PROTECTION:

- | | | | |
|--|--|--|--|
| 20. Sprinkler system maintained with annual test reports provided. | | | |
| 21. Smoke detector/fire alarm system maintained with annual test reports provided. | | | |
| 22. Approved extinguishers mounted properly & in good working order. | | | |
| 23. Cooking suppression systems & hood exhaust properly maintained. | | | |
| 24. Protective guards (such as screens) on fuel burning furnaces or fireplaces provided. | | | |

MEANS OF EGRESS:

- | | | | |
|--|--|--|--|
| 25. All exits & their access (i.e. aisles & corridors) free of obstructions. | | | |
| 26. All locking devices on exit doors are of an approved type. | | | |
| 27. Yards & fencing to allow unobstructed exit to exterior of site. | | | |

At the time of this inspection, the fire safety conditions in this facility were found to be:
 _____ **Satisfactory** _____ **Unsatisfactory**

Inspection by _____ Telephone _____